



Ref. Certif. No.

DE 2-041386

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	AC-DC Rectifier
Name and address of the applicant	OmniOn Power Inc. 601 Shiloh Road Plano TX 75074, USA
Name and address of the manufacturer	OmniOn Power Inc. 601 Shiloh Road Plano TX 75074, USA
Name and address of the factory	See additional page(s)
Ratings and principal characteristics	1) 3 AC 200-240V, 50/60Hz; 19-15A; 2) 3 AC 380-480V, 50/60Hz; 10-8A; Output Ratings: DC 42-58V/115A max., 6000W max.; Class I
Trademark (if any)	OmniOn Power Inc.
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	1) GP100L3RyTEZxxxx, GP100L3MyTEZxxxx, 2) GP100H3RyTEZxxxx, GP100H3MyTEZxxxx (y = 42-58; x = -, 0-9, A-Z; not safety-relevant)
Additional information (if necessary may also be reported on page 2)	Replaces CB Certificate DE 2-032415.
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2018 for national differences see test report
As shown in the Test Report Ref. No. which forms part of this Certificate	32095083 006

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web : www.tuv.com



Date: 2024-03-12

Signature:

Dipl.-Ing. M. Glagla

1. OmniOn Power Shanghai Co., Ltd.
1353 Chenqiao Road
Fengpu Industrial Park
Fengxian
201401 Shanghai, P.R. China
2. Lineage Power Matamoros, S.A. de C.V.
Poniente 2 No. 3 entre Norte
7 y Limite del, Fraccionamiento
Ciudad Industrial (CIMA)
Matamoros Tamaulipas, México CP. 87499, MEXICO

Additional information (if necessary)

Report Ref. No. : 32095083 006



Date: 2024-03-12

Signature:

Dipl.-Ing. M. Glagla