

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50561762

Blatt Sheet
0001

Ihr Zeichen Client Reference
245784212

Unser Zeichen Our Reference
01-Zhangzp-CN221UMA 001

Ausstellungsdatum Date of Issue
18.10.2022 (day/mo/yr)

Genehmigungsinhaber License Holder
ABB Power Electronics Inc.
601 Shiloh Road Plano,
Texas 75074
USA

Fertigungsstätte Manufacturing Plant
Lineage Power China Co., Ltd.
1353 Chengqiao Road
Fengpu Industrial Park
Fengxian
201401 Shanghai
P.R. China

Prüfzeichen Test Mark



Bauart geprüft
Sicherheit
Regelmäßige
Produktions-
überwachung

www.tuv.com
ID 1111260508

Geprüft nach Tested acc. to
EN IEC 62368-1:2020+A11
EN 62368-1:2014+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Einbau-Schaltnetzteil (Switching Power Supply)

Type/Model Designation : 1) CLP0312DC
2) CLPDC0DB
Trademark : GE (Optional)
Rated Input : refer to Appendix No. 1.0
Rated Output : refer to Appendix No. 1.0
Protection Class : Not classified
Max. Operating Altitude : 5000m
Max. Operating Temperature : 75 °C

Remark:

The installation has to be carried out according to the installation instructions accompanying the product.

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

Mark Chen

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935