

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50385075

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
52206931

Unser Zeichen *Our Reference*  
01-SY-50096022 001

Ausstellungsdatum *Date of Issue*  
12.09.2017 (day/mo/yr)

Genehmigungsinhaber *License Holder*  
GE Power Electronics, Inc.  
601 Shiloh Road  
Plano, Texas 75074  
USA

Fertigungsstätte *Manufacturing Plant*  
Refer to latest revision  
of the annex list of factories

## Prüfzeichen *Test Mark*



Bauart geprüft  
Sicherheit  
Regelmäßige  
Produktions-  
überwachung

www.tuv.com  
ID 1419049616

Geprüft nach *Tested acc. to*  
EN 60950-1:2006+A11+A1+A12+A2

Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

Einbau-Schaltnetzteil (Switching Power Supply)

Type Designation : MPR0854, SP805 (GE) 6  
AC input : 100-240 V, 50/60 Hz (or 47-63 Hz), 10-5 A  
DC output : 54 V, 14.82 A, 800 W or 50 V, 16 A, 800 W  
Protection Class : Class I  
Max. Operating Altitude : 4000m  
Max. Operating Temperature: +50 °C  
(refer to operation instruction for details)

### Remark:

Primary and secondary circuits are separated according to method 1 of clause 2.9.4. The installation has to be carried out according to the installation instructions accompanying the product.

6

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 http://www.tuv.com/safety



Mark Chen

Anlage Fertigungsstättenliste  
/Attachment List of Factories



R 50385075 0001

- |   |  |
|---|--|
| 1 Lineage Power China Co., Ltd.<br>1353 Chenqiao Road, Fengpu<br>Industrial Park, 201401, Fengxian<br>Shanghai<br>P. R. China | 2 Lineage Power Matamoros, S.A. de C.V.<br>Poniente 2 No. 3 entre Norte<br>7 y Limite del, Fraccionamiento<br>Ciudad Industrial (CIMA)<br>Matamoros Tamaulipas, México CP. 87499, MEXICO |
|---|--|



Zertifizierungsstelle  
/ Certification Body

  
Mark Chen

Datum / Date 12.09.2017

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

GE Power Electronics, Inc.

Date : 12.09.2017

Our ref. : SY 01

Your ref.: 52206931

601 Shiloh Road  
Plano, Texas 75074  
USA

**Ref : R TÜV-Mark Approval**

Type of Equipment : Switching Power Supply  
Model Designation : See Certificate  
Certificate No. : R 50385075 0001  
Report No. : 50096022 001

Dear Ladies and Gentlemen,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

  
Mark Chen

Enclosure


证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

**Produkte**  
**Products**
**Certificate No.:** R 50385075 0001 **Report No.:** 50096022 001 **Appendix No.** 1.0

Blatt Page

**Constructional Data Form (CDF) for Electrical Appliances**

Page 1 of 6

License Holder (Name and Address)	:	GE Power Electronics, Inc. 601 Shiloh Road, Plano, Texas 75074, USA
Factory(ies) (Name and Address)	:	1) Lineage Power China Co., Ltd. 1353 Chenqiao Road, Fengpu Industrial Park, 201401, Fengxian, Shanghai, P.R. China  2) Lineage Power Matamoros, S.A. de C.V. Poniente 2 No. 3 entre Norte 7 y Limite del, Fraccionamiento Ciudad Industrial (CIMA) Matamoros, Tamaulipas México CP. 87499, MEXICO
Type of Appliance	:	Switching Power Supply
Brand Name/Trademark	:	 (GE)
Type Designation	:	MPR0854, SP805
Rating	:	AC input: 100-240 V, 50/60 Hz (or 47-63 Hz), 10-5 A DC output: 54 V, 14.82 A, 800 W or 50 V, 16 A, 800 W
Class of equipment	:	Class I Equipment
Class of IP	:	IPX0
Supply connection	:	Input connector
Equipment mobility	:	Built-in Equipment
Operation ambient	:	Up to 50 °C
Operation altitude	:	Up to 4000 m
Operation condition	:	Continuous
Additional information	:	--

**TÜV Rheinland Group**
**GE Power Electronics, Inc.**

2017.09.12 Sunny Sun

Date

Printed Name

Signature



2017.09.12

Date

Andy Huang

Printed Name

Stamp &amp; Signature of licenseholder

